



MAHARSHI DAYANAND UNIVERSITY, ROHTAK
NOTICE INVITING QUOTATIONS

Sealed percentage/item rate quotations are hereby invited by the undersigned for and on behalf of Registrar, M.D. University, Rohtak for the below noted work from the suppliers/Agencies/Contractors/societies registered with Haryana P.W.D. B & R, M.E.S. & Central P.W.D. UHBVN/DHBVN or any other State/Central Govt. Department for electrical works on dated 28/03/2024 at 3 P.M. Quotations will be opened at the same date and time in the presence of quotationers or representative who may like to be present at that time. However, preference will be given to societies first, if two or more societies participated and found eligible. DNIQ may be seen on University website or in the office of Sub-Division.

Description	App.Amt.	Earnest Money	Time Limit
"S/E of earthing and electrical work in ACIL, M.D. Rohtak",			24746/-

Conditions: -

1. The work will be carried out strictly in accordance with the PWD Haryana specification and approved DNIQ.
2. Other taxes will be deducted as applicable time to time.


Sub-Divisional Engineer (Elect.)
M.D. University, Rohtak. 



SDE/(Elect.)/2024/ 153-55 Dated 21/3/2024

Cope of the above is forwarded to the following for information and necessary action:-

The Executive Engineer, M.D. University, Rohtak

Notice Board

Contractors/Agencies


Sub-Divisional Engineer (Elect.)
M.D. University, Rohtak. 

DNIT for "S/E of Earthing and electrical work in ACIL , M.D.U. Rohtak".

Sr. No.	HSR/ NS	Description of items	Qty.	Unit	Rate to be quoted by Agency
1	23.22.5.3	Supply and erection of miniature circuit Breaker 240/415 V in the existing distribution board including making necessary connections:-6 amp. to 32 amp Double POLE	each	1	
2	24.1.4	Earthing with tinned copper earth plate 600mmx600mmx3mm thick including accessories and providing masonry enclosures with cover plate having locking arrangement and watering pipe etc. (but without charcoal or coke and salt) etc. complete as required.	each	1	
3	24.1.5	Extra for charcoal or coke and salt for G. I. plate or copper plate earth electrode.	each	1	
4	24.1.9	Providing and fixing 25 mm x5 mm copper strip in 40 mm dia G.I. pipe from earth electrode as required.	metre	5	
5	24.1.10	Providing and fixing 25 mm x 5mm copper strip on surface or in recess for connections etc. as required with all labour and material.	metre	8	
6	24.1.13	Providing and fixing 4.00 mm dia G1. Wire on surface or in recess for loop earthing as required.	metre	10	
7	NS 1	Supply and erection of 3 Pin Industrial Male Female Connector with SPN Enclosure.	each	1	